



**CONCEPTUAL DRAWING
SANITARY SERVICE LINE MAY
VARY IN EACH HOME

CODE REFERENCE ON SUMP:
NATIONAL BUILDING CODE SECTION 9.14.2
FOUNDATION DRAINAGE
9.14.5.2 SUMP PITS

SUMP PIT MAY BE CONSTRUCTED OF:
A) CONCRETE
B) CORROSION RESISTANT STEEL
C) PLASTIC

WHERE A SUMP PIT IS PROVIDED IT SHALL BE:
A) NOT LESS THAN 750mm DEEP.
B) NOT LESS THAN 0.25sq.m IN AREA, AND
C) PROVIDED WITH A COVER.

REVISIONS	
1	
2	
3	
DRAWN BY <u>C. CARTER</u>	
DATE <u>05/05/03</u>	
CHECKED BY _____	
DATE _____	



**City of
Saskatoon**
Infrastructure Services Department

SUMP WITH PUMPED DISCHARGE
TO SURFACE

APPROVED	
GENERAL MANAGER	P. ENG.
ENGINEER	_____
ENGINEER	_____
SCALES :	HOR. <u>NTS</u> _____
PLAN NO.	_____